



FRESNO COUNTY FIRE

PROTECTION DISTRICT

DRAFT HYDRANT GUARD POST DETAIL

1. GUARD POST SHALL BE 4" GALV. OR SCH. #40 PIPE.
2. GUARD POST SHALL BE SOLID CONCRETE FILLED
3. GUARD POST SHALL HAVE BLUE REFLECTIVE MARKER WHICH FACES THE DRIVE AISLE.
4. GUARD POST SHALL BE SPACED AS SHOWN ABOVE.

FIRE SAFETY STANDARDS

DATE: JULY 27, 2017

SCALE: NO SCALE

STANDARD NO.

2C

REVISION DATE:

