

ORDINANCE NO. 2016 - 01

AN ORDINANCE OF THE FRESNO COUNTY FIRE PROTECTION DISTRICT ADOPTING THE 2016 EDITION OF THE CALIFORNIA FIRE CODE, AMMENDING THOSE PORTIONS IDENTIFIED HEREINUNDER, AND REPEALING ALL CONFLICTING ORDINANCES AND PARTS OF ORDINANCES.

The Board of the Fresno County Fire Protection District does ordain as follows:

**SECTION 1:**

The 2016 Edition of the California Code of Regulations, Title 24, Part 9, the California Fire Code, including all Appendices as published by the International Code Council, three copies of which are on file in the office of the Fire Chief of the Fresno County Fire Protection District and available for inspection by the public, is adopted as the Fire Code of the Fresno County Fire Protection District as fully set forth in this Ordinance, save and except those insertions, deletions and changes prescribed in Section 3 of this Ordinance.

**SECTION 2:**

WHEREAS, Health and Safety Code Section 13869.7 establishes that a fire protection district may be recognized as the Authority Having Jurisdiction for purposes of adopting and amending the California Code of Regulations, Title 24, Part 9 (the California Fire Code); and

WHEREAS, Health and Safety Code Sections 17958 and 18941.5 establishes the procedures for adoption and amendment of the California Code of Regulations, Title 24, Parts 1 through 12; and,

WHEREAS, the Fresno County Fire Protection District recognizes that there are significant and disparate conditions that exist within the boundaries of the District; and,

WHEREAS, the Fresno County Fire Protection District recognizes that these conditions must be climatic, geological, and/or topographical in nature in order for a local Authority Having Jurisdiction to make amendments; and,

WHEREAS, the Fresno County Fire Protection District desires to establish appropriate means and measures to protect the welfare of the citizens, property and uninhabited land of the district;

NOW THEREFORE, BE IT RESOLVED BY BOARD OF DIRECTORS OF THE FRESNO COUNTY FIRE PROTECTION DISTRICT AS FOLLOWS:

1. The above recitals are true and correct.
2. The Board of Directors finds that the climatic conditions within the boundaries of the Fresno County Fire Protection District create significant climatic issues which create drought in many portions of the district and that drought directly affects the available water supplies, including those used in fire suppression activities.
3. The Board of Directors finds that the topographic conditions within the boundaries of the Fresno County Fire Protection District create significant issues for Fire Access and Fire Operations in many portions of the district. Such issues include roads that are too steep to drive fire apparatus on, roadways that are blocked by snow or ice, structures built where access is limited due to intervening topographic features or are prone flooding or mudslides.
4. The non-administrative amendments to the California Code of Regulations, Title 24, Part 9, the California Fire Code are needed due to the climatic and topographic conditions indicated in items #2 and #3 above. These amendments are to the California Fire Code Sections as listed below in Section 3.

### **SECTION 3:**

The following Sections of California Fire Code are amended as follows:

**Section 101.1 Title**; replace "[NAME OF JURISDICTION]" with "Fresno County Fire Protection District".

**Section 108.1, Board of Appeals**; delete, "The board of appeals shall be appointed by the governing body and shall hold office at its pleasure. The fire code official shall be an ex officio member of said board but shall have no vote on any matter before the board."

**Section 108.3, Qualifications**; delete in its entirety.

**Section 109.4, Violation Penalties**; replace "[SPECIFY OFFENSE]" with "Misdemeanor".

**Section 109.4, Violation Penalties**; replace "[AMOUNT]" with "\$500.00".

**Section 109.4, Violation Penalties**; replace "[NUMBER OF DAYS]" with "90 days".

**Section 113.2, Fees**; replace "applicable governing authority" with "Fresno County Fire Protection District".

**Section 507.2.3, Reservoirs**; added section, "507.2.3 Reservoirs. Reservoirs shall meet the requirements of Sections 507.2.3.1 through 507.2.3.4.

507.2.3.1 Lining. All reservoirs used as part of the fire flow supply system shall be lined in accordance with nationally recognized standards.

507.2.3.2 Treatment. All reservoirs used as part of a fire flow supply system shall be chemically treated to maintain proper water balance and pH levels in accordance with nationally recognized standards.

507.2.3.3 Measurement. All reservoirs used as part of a fire flow supply system shall be provided with a system for measurement of the supply volume and a system for automatic refilling of the reservoir should the supply volume be reduced to less than 80% of the required volume.

507.2.3.4 Maintenance. All reservoirs used as part of a fire flow supply system shall be maintained in accordance with NFPA 25 and nationally recognized standards. "

**Section 5704.2.9.6.1, Locations where above-ground tanks are prohibited;** replace"(see Section 3 of Sample Ordinance for Adoption of the California Fire Code on page xxv)" with "where determined by the Fire Code Official".

**Section 5706.2.4.4, Locations where above-ground tanks are prohibited;** replace "(see Section 3 of Sample Ordinance for Adoption of the California Fire Code on page xxv)" with "where determined by the Fire Code Official".

**Section 5806.2, Limitations;** replace"(see Section 3 of Sample Ordinance for Adoption of the California Fire Code on page xxi)" with "where determined by the Fire Code Official".

**Section 6104.2, Maximum capacity within established limits;** replace"(see Section 3 of Sample Ordinance for Adoption of the California Fire Code on page xxi)" with "or as determined by the Fire Code Official".

**Appendix A, "Board of Appeals";** omit all of Section A101 and replace it with the Fresno County Fire Protection District Board of Appeals procedures, provided as Attachment A to this Ordinance.

**Appendix B, Section B103.3;** revise (as shown in italics) "... NFPA 1142 as amended by the Fresno County Fire Protection District. *Systems may be pressurized to meet the required flow. Systems requiring the drafting of non-pressurized water supplies are permitted as specified in FCFPD Policies and Standards.*"

**Appendix B, Section BB105.2 Exception I;** revise (as shown in italics)"...*fire flow of 50 percent, as approved...*"

**Appendix B, Section BB105.2 Exception I;** add (as shown in italics)" ... as specified in Table BBI05.1. *The pump pressurizing the fire flow shall be capable of providing the required fire flow and any fire sprinkler demands at not less than 20 psi residual pressure at the most remote location served.*

**SECTION 4:**

All other Ordinances or parts of Ordinances in conflict with this Ordinance are repealed.

**SECTION 5:**

If any section, subsection, sentence, clause or phrase of this Ordinance is for any reason held to be unconstitutional, such decision shall not affect the validity of the remaining portions of this Ordinance. The Board of Directors of the Fresno County Fire Protection District declares that it would have passed this Ordinance and each section, subsection, sentence, clause or phrase thereof irrespective of the fact that any one or more sections, subsections, sentences, clauses, or phrases be declared unconstitutional.

**SECTION 6:**

Nothing in the Ordinance shall be construed to affect any suit or proceeding impending in any court, or any rights acquired, or liability incurred, or any cause or causes of action acquired or existing, under any act or Ordinance repealed by this Ordinance; nor shall any just or legal right or remedy of any character be lost, impaired, or affected by this Ordinance.

**SECTION 7:**


The Clerk of the Fresno County Fire Protection District Board of Directors is ordered and directed to cause this Ordinance to be published in accordance with the provisions of Government Code Section 25124. Furthermore the Clerk of the Fresno County Fire Protection District Board of Directors is ordered and directed to cause this Ordinance to be filed with the California Building Standards Commission in accordance with the CBSC's requirements.

**SECTION 8:**

This Ordinance shall take effect on January 1, 2017


The foregoing Ordinance was PASSED, APPROVED, and ADOPTED at a regular meeting of the Board of Directors of the Fresno County Fire Protection District held on the 7<sup>th</sup> of December 2016 by the following vote:

AYES 6  
NOES 0  
ABSENT 1  
ABSTAIN 0




Michael Del Puppo, President  
Fresno County Fire Protection District  
Board of Directors

ATTEST:



Geraldine Welford, Clerk  
Fresno County Fire Protection District  
Board of Directors

APPROVE AS TO FORM:



William D. Ross, District Council