



FRESNO COUNTY FIRE

PROTECTION DISTRICT

210 South Academy Avenue
Sanger, California 93657
Telephone: (559) 493-4300
Fax: (559) 875-7451
www.FresnoCountyFire.org

Teachers Classroom Fire and Life Safety Inspection Checklist

Fire Extinguishers

- Fire extinguisher shall have nothing hanging or covering it and shall not be obstructed from view at any time.
Complete Pending
- The fire extinguisher (if present) shall be immediately available and plainly visible near the exit door of class room .
Complete Pending
- It needs to be mounted to the wall no higher than 5 feet above the floor.
Complete Pending
- Professional service is needed on each extinguisher annually or immediately after use.
Complete Pending
- Monthly visual inspections of each extinguisher shall be completed by staff.
Complete Pending



Fire Alarm Pull Station

- The Pull Station shall have nothing hanging or covering it and shall not be obstructed from view at any time.
Complete Pending
- The Fire Alarm Panel should not show “trouble” or “ground fault.”
Complete Pending
- The Fire Alarm Panel batteries must be professionally serviced annually
Complete Pending

Electrical

- There shall be no missing or broken electrical cover plates.
Complete Pending
- If there is a breaker box located in the classroom, there shall be nothing covering or obstructing the view and access to the box.
Complete Pending
- Electrical cords shall not be a trip hazard; cords that are over walking areas must have an approved protective transition and must not be placed under a rug.
Complete Pending
- Remove extension cords, extension cords shall not be used as a substitute for permanent wiring. Extension cords shall be used only with temporary used portable appliances.
Complete Pending
- Electrical surge protectors shall be directly connected to a permanently installed receptacle and shall not be plugged into each other.
Complete Pending



Decorative Materials/Storage

- Doors shall not be concealed by curtains, drapes, decorations or similar materials.
Complete Pending
- 3D decorations on walls shall be made from flame-retardant materials.
Complete Pending
- Breaker boxes and electrical panels shall not be covered at any time.
Complete Pending
- Artwork and teaching materials shall be limited on walls of classrooms to not more than 50% of the specific wall area to which they area attached.
Complete Pending
- Decorative materials shall not completely obscure windows
Complete Pending

806.3 Combustible decorative materials. In other than Group 1-3, curtains, draperies, fabric hangings and similar combustible decorative materials suspended from walls or ceilings shall comply with Section 807.4 and shall not exceed 10 percent of the specific wall or ceiling area to which such materials are attached.