



FRESNO COUNTY FIRE


PROTECTION DISTRICT

210 South Academy Avenue
Sanger, California 93657
Telephone: (559) 493-4300
Fax: (559) 875-7451
www.FresnoCountyFire.org

Teachers Classroom Fire and Life Safety Inspection Checklist

Fire Extinguishers

- Fire extinguishers (if present) shall be immediately available for usage and plainly visible near the exit door of classroom.
Complete Pending
- Fire extinguishers shall be mounted to the wall so that the top is no more than 5 feet from the floor, and the bottom is at least 4 inches from the floor.
Complete Pending
- Fire extinguishers shall be professionally serviced and tagged annually, or immediately after use.
Complete Pending
- Monthly visual inspections of each extinguisher shall be completed by staff.
Complete Pending



Fire Alarm Pull Station

- A fire alarm pull station shall have nothing hanging or covering it and shall not be obstructed from view at any time.
Complete Pending
- The Fire Alarm Panel should not show “trouble” or “ground fault.”
Complete Pending
- Fire Alarm Panel batteries shall be professionally serviced annually.
Complete Pending

Electrical

- There shall be no missing or broken electrical cover plates.
Complete Pending
- Breaker boxes and electrical panels (if present) shall maintain a 36 inch clearance in front of the panel.
Complete Pending
- Breaker boxes and electrical panels shall not be concealed at any time.
Complete Pending
- Electrical cords shall not be a trip hazard. Cords that are over walking areas must have an approved protective transition and must not be placed under a rug.
Complete Pending
- Extension cords shall not be used as a substitute for permanent wiring and have a 90 day max usage period. Extension cords shall only be used with low voltage equipment.
Complete Pending
- Electrical surge protectors shall be directly connected to a permanently installed receptacle and shall not be plugged into each other.
Complete Pending



Decorative Materials

- Doors shall not be concealed by curtains, drapes, decorations or similar materials.
Complete Pending
- Decorative materials shall not completely obscure windows.
Complete Pending
- 3D decorations on walls shall be made from flame-retardant materials.
Complete Pending
- Artwork and teaching materials shall be limited on walls of classrooms to not more than 50% of the specific wall area to which they are attached.
Complete Pending
- Combustible decorative materials suspended from ceilings shall not exceed 10 percent of the specific ceiling area to which they are attached.
Complete Pending