



# FRESNO COUNTY FIRE


PROTECTION DISTRICT

1700 Jensen Avenue  
Sanger, California 93657  
Telephone: (559) 319-0400  
Fax: (559) 272-2410  
[www.fresnocountyfire.org](http://www.fresnocountyfire.org)

## Teachers Classroom Fire and Life Safety Inspection Checklist

### Fire Extinguishers and Exiting

- Fire extinguishers shall be immediately available for use and plainly visible near the exit door of the classroom.  
Complete  Pending
- Fire extinguishers shall be mounted to the wall so that the top is no more than 5 feet from the floor, and the bottom is at least 4 inches from the floor.  
Complete  Pending
- Fire extinguishers shall be professionally serviced and tagged annually, or immediately after use.  
Complete  Pending
- Monthly visual inspections of each extinguisher shall be completed by staff.  
Complete  Pending
- Each classroom shall be equipped with exit signage above the exit door, and an emergency evacuation map.  
Complete  Pending



### Fire Alarm

- A fire alarm pull station shall have nothing hanging or covering it, and shall not be obstructed from view at any time.  
Complete  Pending
- The Fire Alarm Panel shall not show "trouble" or "fault" and shall be serviced annually.  
Complete  Pending
- Fire Alarm Panel batteries shall be replaced every 5 years from the date of installation.  
Complete  Pending

## Electrical



- There shall be no missing or broken electrical outlet cover plates.  
Complete  Pending
- Breaker boxes and electrical panels shall maintain a 36 inch clearance in front of the panel.  
Complete  Pending
- Breaker boxes and electrical panels shall not be concealed at any time.  
Complete  Pending
- Electrical cords shall not be a trip hazard. Cords that are over walking areas must have an approved protective transition and shall not be placed under a rug.  
Complete  Pending
- Extension cords shall not be used as a substitute for permanent wiring and have a 90 day max usage period.  
Complete  Pending
- Electrical surge protectors and extension cords shall be plugged directly to a wall outlet and shall not be daisy chained together.  
Complete  Pending
- High powered appliances such as microwaves, heaters, and fridges shall be plugged directly to a wall outlet and shall not be plugged into a surge protector or extension cord.  
Complete  Pending

## Decorative Materials

- Doors shall not be concealed by curtains, drapes, decorations, or similar materials.  
Complete  Pending
  - 3D decorations and decorative fabrics shall be made from flame-retardant materials.  
Complete  Pending
  - Artwork and teaching materials shall be limited on walls of classrooms to not more than 50% of the specific wall area to which they are attached.  
Complete  Pending
  - Combustible decorative materials suspended from ceilings shall not exceed 10% of the specific ceiling area to which they are attached.  
Complete  Pending
- 
-